

Improvement of the Power Quality of Grid-Connected Solar PV Systems by the Use of an Adaptive Noise Reduction and Frequency Control Loop

Dr.T.Charan Singh¹, Mr.G.Praveen kumar², Mr.T.Ramesh³, Mr. R.Sandeep⁴

ASSOCIATE PROFESSOR¹, ASSIT. PROFESSOR², ASSIT. PROFESSOR³, ASSIT.PROFESSOR⁴

Department of EEE

SWARNA BHARATHI INSTITUTE OF SCIENCE & TECHNOLOGY (SBIT)

ABSTRACT

A three-phase VSC that has served several purposes is integrated into a two-stage, three-phase PV-grid interfaced system in this project. By using an adaptive noise reduction strategy, a multifunctional VSC may be regulated to transfer active power from PV systems to the grid while simultaneously improving the power quality at AC mains as an active power filter (APF). The management approach outlined here is quick and precise in its dynamic responses. The proposed SPV energy system has been implemented to show that harmonic removal, load balancing, and power factor modification can be achieved with both linear and non-linear loads. To minimize

disturbances on both the load and grid sides, a frequency loop and a fuzzy logic-based complex dc voltage control loop are used. A multifunctional VSC is regulated using an adaptive noise reduction approach. It serves as an active power filter (APF) to enhance power quality at AC mains and transmits active power from PV systems to the grid. Adapting swiftly and accurately to changing conditions is the hallmark of the management style described here. By applying the suggested SPV energy system to both linear and non-linear loads, we can see how it eliminates noise, balances loads, and corrects for power factor.

inverter designs. Achieving maximum power point tracking (MPPT), load control,

and power quality at the interaction of PV with the grid, such as harmonics elimination, load balancing, etc., are some of the difficulties that come with integrating PV into the grid.



Several of them talk about the system's power quality improvement, but their

INTRODUCTION

Grid connected solar photovoltaic (PV) systems are now a significant field of study due to the rise in demand for renewable energy sources. Moreover, the grid-connected PV system is becoming far more alluring due to the steep decline in cost and rise in efficiency of PV panels, as well as the appearance of less expensive and creative

discussion is confined to simulation studies with no mention of the hardware. In this paper, we provide a control that aims to accomplish the following To take advantage of the inverter's capabilities to compensate for reactive power loss while also transferring solar energy in a grid-integrated solar PV system. To improve the system's power quality at the AC mains. When there is no solar power generation, the inverter typically sits idle, but a smart inverter with reactive power capabilities can be used constantly. The overall cost of installing solar PV will be lower thanks to such a multi-functional inverter. The proposed system can perform a variety of tasks in addition to the inverter's multifunctionality, including solar power transfer to the grid and loads, including load balancing with both linear and non-linear loads, harmonic compensation at the AC mains, power factor correction, and MPPT tracking. A rapid and accurate dynamic response is also provided by the control mechanism discussed here, which is also very robust and simple to implement in both software and hardware.

Proposed SYSTEM CONFIGURATION



A complete schematic diagram of the proposed system in which a grid is interfaced with a solar PV generating system using a three-leg VSC. The configuration consists of SPV panels, a DC-DC boost converter, interfacing inductors, a ripple filter and a VSC with a two stage control system MPPT control and inverter control.

Two stage control algorithms are used in the proposed system. First stage is maximum power point tracking (MPPT) which is used to control DC-DC boost converter whereas the second stage is to control VSC switching. For VSC control, a new control algorithm called adaptive noise reduction (ANR) has been used in this work.

In order to minimize disturbances at the load and grid side, a sophisticated dc voltage control loop with fuzzy logic and a frequency loop are employed. Multifunctional VSC, which transmits active power from PV systems to the grid and also serves as an active power filter (APF) to enhance power quality at AC mains, is controlled using an adaptive noise reduction method. The management method described here responds dynamically with speed and accuracy. With linear and non-linear loads, the suggested SPV energy system has been put into practice to demonstrate harmonic removal, load balancing, and power factor adjustment. An inverter is an electrical device that converts direct current (DC) to alternating current (AC); the converted AC can be at any

required voltage and frequency with the use of appropriate transformers, switching, and control circuits. Solid-state inverters have no moving parts and are used in a wide range of applications, from small switching power supplies in computers, to large electric utility high-voltage direct current applications that transport bulk power. Inverters are commonly used to supply AC power from DC sources such as solar panels or batteries.

There are two main types of inverter. The output of a modified sine wave inverter is similar to a square wave output except that the output goes to zero volts for a time before switching positive or negative. It is simple and low cost (~\$0.10USD/Watt) and is compatible with most electronic devices, except for sensitive or specialized equipment, for example certain laser printers. A pure sine wave inverter produces a nearly perfect sine wave output (<3% total harmonic distortion) that is essentially the same as utility-supplied grid power. Thus it is compatible with all AC electronic devices. This is the type used in grid-tie inverters. Its design is more complex, and costs 5 or 10 times more per unit power (~\$0.50 to \$1.00USD/Watt). The electrical inverter is a high-power electronic oscillator. It is so named because early mechanical AC to DC converters was made to work in reverse, and thus was "inverted", to convert DC to AC. The inverter performs the opposite function of a rectifier.

This inverter is similar to the half-bridge inverter; however, a second leg provides the neutral point to the load. As expected, both switches S1 and S1̄ (or S2 and S2̄) cannot be on simultaneously

because a short circuit across the dc link voltage source V_i would be produced. There are four defined and one undefined

The undefined condition should be avoided so as to be always capable of defining the ac output voltage. In order to avoid the short circuit across the dc bus and the undefined ac output voltage condition, the modulating technique should ensure that either the top or the bottom switch of each leg is on at any instant. It can be observed that the ac output voltage can take values up to the dc link value v_i , which is twice that obtained with half-bridge VSI topologies. Several modulating techniques have been developed that are applicable to full-bridge VSIs. Among them are the PWM (bipolar and unipolar) techniques.

The conversion of solar radiation occurs by the photovoltaic effect which was first observed by Becquerel. It is quite generally defined as the emergence of an electric voltage between two electrodes attached to a solid or liquid system upon shining light onto this system. Energy conversion devices which are used to convert sunlight to electricity by the use of the photo-voltaic effect are called solar cells. Single converter cell is called a solar cell or more generally photovoltaic cell and combination of such cells designed to increase the electric power output is called a solar module or solar array and hence the name 'Photovoltaic Arrays'. Solar cells can be arranged into large groupings called arrays. These arrays, composed of many thousands of individual cells, can function as central electric power stations, converting sunlight into electrical energy for distribution to industrial, commercial and

residential users. Solar cells in much smaller configurations are commonly referred to as solar cell panels or simply panels. Practically, all photovoltaic devices incorporate a P-N junction in a semiconductor across which the photo voltage is developed. The solar panels consist mainly of semiconductor material, with Silicon being most commonly used.

Current-type converters have advantages of excellent current controllability, easy protection and high reliability over Voltage source APF. Moreover CSI topology has superior characteristics compared to VSI topology in terms of direct injected current, which result in a faster response in time varying load environment and lower dc energy storage requirement. The drawback of the current source APF is larger power losses of the dc-link inductor. However, the current-type active power filter will become more attractive when the super conducting coils are available in the future. Losses are less important in low- power applications but very important in high power applications.

Since they are easily expandable, voltage type APF's are likely to be used for network wide compensation. Current type APF's will continue to popular for single-node distortion problems. In other words, electric utility interest will likely to be focused on voltage type converters, while industrial users likely to use both type of converters.

SIMULATION RESULTS




Fig 1 simulation circuit




Fig 2. Converter voltage and current, filter currents



Fig3. Load voltage and load current, grid voltage

CONCLUSION

A three-phase two stage SPV energy conversion system has been implemented on hardware. A new ANR control technique has been proposed and implemented for estimation of reference supply current to generate the switching pulses for VSC. The implemented control algorithm has been found to provide acceptable characteristics in all the situations. The performance of the multifunctional VSC has been demonstrated for harmonic elimination, power factor correction, load balancing, reactive power compensation and transfer of solar power under balanced and unbalanced load condition for both linear and non-linear loads. Solar power from the solar simulator has been successfully fed to the grid and overall performance of the proposed grid interfaced SPV energy system has been found satisfactory under different operating conditions. The reactive power compensation capability of the inverter has been demonstrated in addition to solar power transfer. This makes it possible to utilize inverter at night time when there is no solar power generation. This will definitely result in improved efficiency and reduced cost of solar PV system.

REFERENCES

- Renewable Energy Systems with Photovoltaic Power Generators: Operation and Modeling, by J.T. Bialasiewicz Industrial
- Electronics, vol.55, no.7, pp.2752-2758, July 2008, published by IEEE. "Grid Integration of Small-Scale Photovoltaic Systems in Secondary
- Distribution Network—A Review," by R. Panigrahi, S. Mishra, S. C. Srivastava, A. K. Srivastava, and N. Schulz Industrial Applications, 2020, IEEE Transactions on, Early Access
- Using Battery Energy Storage for Real-Time Coordinated Voltage Support in a Distribution Grid with Medium-Scale PV Generation, J. Krata and T. K. Saha May 2019, IEEE Transactions on SmartGrid, vol. 10, no. 3, pp. 3486-3497.
- 4. "A Charging Strategy for PV-Based Battery Switch Stations Considering Service Availability and Self-Consumption of PV Energy," by N. Liu, Q. Chen, X. Lu, J. Liu, and J. Zhang published in August 2015 by IEEE Transactions on Industrial
- Electronics, volume 62, issue 8, pages 4878–4889. Y. Shan, J. Hu, K. W. Chan, Q. Fu, and J. M. Guerrero, "A New Control Method for PV-Wind-Battery Microgrids - Model Predictive Control of Bidirectional DC-DC Converters and AC/DC
- Interlinking Converters," EarlyExcess2018,
- IEEE Trans.SustainableEnergy. V. Rallabandi, O. M. Akeyo, N. Jewelland"
- The Integration of Battery Energy Storage Systems into

- Multi-MW Grid-Connected Photovoltaic Systems," by D.M.
- Ionelpublication date: January 2019 to February 2019; volume: 55, issue: 1, pages 638-647.
 -
 - [7] "Energy Management and Control of Single-Stage Grid-Connected Solar PV and BES System," by H. Myneni and G.
 - Siva Kumar,2019 IEEE Transactions on Sustainable Energy, Early Access.
 -
 - (Hybrid power electronic controller for combined operation of constant power and maximum power point tracking for single-phase grid-tied solar systems) [8] B. B. J. Dharmaian Retnam,
 - A. G. Nanjappa Gounder, and V. Ammasai Gounden, IET Power Electronics, vol. 7, no. 12, pp. 3007-3016, Dec. 2014.
 - The authors of the article "IntegratedSizeandEnergyManagementDesign of Battery Storage to Enhance Grid Integration of Large-Scale PV Power Plants" (Y. Yang, Q. Ye, L. J. Tung, M. Greenleaf, and H. Li, 2018) presented their findings in the IEEE Transactions on Industrial Electronics.
 - 10. "Novel Predictive Fuzzy Logic-Based Energy Management System for Grid-connected and Off-grid Operation of Residential Smart Micro-grids" by M. Jafari, Z. Malekjamshidi, J. Zhu, and M. Khooban was published in the 2018 early edition of the IEEE Journal of Emerging and Selected Topics in Power Electronics.
 - "A Robust Power Management Strategy with Multi-Mode Control Features for an Integrated PV and Energy Storage System to Take the Advantage of ToU Electricity Pricing" (March-April 2019) by V. T. Tran, K. M. Muttaqi, and D. Sutanto was published in the IEEE Transactions on Industry Applications.
 - "Control and operation of a solar PV-battery-grid-tiedsystem in fixed and variable power mode" (IET Generation, Trans. & Distr., vol. 12, no. 11, pp. 2633-2641, 2018) was written by N. Beniwal, I. Hussain, and B. Singh.
 - The authors of the paper "Transition Control Strategy between Standalone and Grid-Connected Operations of Voltage Source Inverters" are M. N. Arafat, S. Palle, Y. Sozer, and I. Husain.
 - IEEE Transactions on Industrial Applications, volume 48, issue 5, pages 1516–1525, September 2012–October 2012, vol. 50.
 - Dual-Mode Control of a Three-Phase Inverter Using Minimum

Variance Adaptive Architecture,
by R. Bhattarai, N. Gurung, and
S. Kamalasan

- [14] published in July-August 2018 in the IEEE Transactions on Industrial Applications, volume 54, issue 4, pages 3868–3880.
- [15] Harmonic Control in Electric Power Systems: IEEE Recommended Practice and Requirements, IEE Standards 519-2014, pages 1–29, June 11, 2014.
- A novel hybrid filter-based PLL to eliminate the effect of input harmonics and DC offset was proposed by N. Hui, D. Wang, and Y. Li in [16]. 19762–19773, 2018: IEEE Access, volume 6.
- In their paper titled "An Efficient Technique Using Modified p-q Theory for Controlling Power Flow in a Single-Stage Single-Phase Grid-Connected PV System," A. Datta, R. Sarker, and I. Hazarika (17)
- Industrial Informatics, Volume 15, Issue 8, Pages 4635–4645, August 2019, published by IEEE.
- In their article "Problems of Startup and Phase Jumps in PLL Systems" published in April 2012 in the IEEE Transactions on Power Electronics, the authors Karimi Ghartemani, Khajehoddin, Jain, and Bakhshai discuss these issues.
- "Fixed-reference-frame phase-locked loop for grid synchronization under imbalanced operation," [19] M. Hernandez-Gomez IEEE Transactions on Industrial Electronics, volume 58, issue 5, pages 1943–1951, May 2011.
- [20] Golestan et al., "Advanced Single-Phase DSC-Based PLLs," Guerrero et al., J. C. Vasquez, Abusorrah A. M., and AlTurki Y. April 2019, volume 34, issue 4, pages 3226–3238, IEEE Transactions on Power Electronics.
- "An Improved Delayed Signal Cancellation PLL for Fast Grid Synchronization Under Distorted and Unbalanced Grid Conditions," by Q. Huang and K. Rajashekara, [21] Vol.53, no.5, pp.4985–4997, Sept.-Oct. 2017, IEEE Transactions on Industry Applications.